

Memorandum

To: Bassett Creek Watershed Management Commission
From: Barr Engineering Company
Subject: Items on the BCWMC March 17, 2005 Meeting Agenda
Date: March 9, 2005
Project: 23/27 051 2005 001

New Business

1. Golden Valley 2005 Pavement Management Program

Summary

Proposed Work: Street reconstruction plan

Basis for Commission Review: Street reconstruction greater than 1 acre

Recommendation: Conditional approval

A request was received for review of a street reconstruction project in the City of Golden Valley. The project includes utility, curb and gutter and sidewalk improvements and the reconstruction of approximately 4.0 miles of residential and commercial streets in the Bassett Creek watershed. The project is located in the Main Stem and Sweeney Lake watersheds and includes Noble Avenue, June Avenue, Culver Avenue, 34th Avenue, Major Avenue, Lee Avenue, Kyle Avenue, Elmdale Avenue, Adell Avenue, Cross Lane, Kyle Place, Valleywood Circle, Indiana Avenue, Wasatch Lane, Hampshire Avenue, Florida Avenue, Dakota Avenue and Brunswick Avenue. Approximately 29 acres in the Bassett Creek watershed will be disturbed as a result of the project. Runoff discharges through existing storm sewers to the Main Stem of Bassett Creek, North Rice Lake and to Sweeney Lake. Construction is proposed during 2005.

Temporary erosion control features including silt fence, flotation silt curtain, inlet protection and street sweeping will be implemented during construction. Additional water quality ponding is not proposed due to unavailable property in the fully developed project area. Permanent BMPs include construction of one environmental sump manhole along Kyle Place for sediment removal prior to discharge to Sweeney Lake. Six sump manholes will be installed throughout the project area to trap sediment prior to discharging to receiving waters.

To: Bassett Creek Watershed Management Commission
From: Barr Engineering Company
Subject: Items on the BCWMC March 17, 2005 Meeting Agenda
Date: March 9, 2005
Project: 23/27 051
Page: 2

Recommendation: Approval, contingent on the following comments:

- a. Details for sump manholes must be provided on the drawings.
- b. Sump manholes must be maintained and inspected at least twice a year.
- c. Final construction plans must be provided to the BCWMC staff for final review and approval.

Old Business

2. Lakeview Park Pond

See discussion in the attached December 16, 2004 meeting minutes.

3. Information Only

- a. Erosion Control Inspection Report
Erosion control inspections will begin April 2005 and extend through October 2005.
- b. Stonebridge Condos
A grading, drainage, and erosion control plan was reviewed for the proposed development. A letter of recommendation was sent to the city of St. Louis Park.
- c. 16 Kaiser Avenue
A single family home was reviewed adjacent to Medicine Lake. A letter was sent to the city of Medicine Lake.